

SECTION 01 51 26
TEMPORARY LIGHTING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Requirements for Temporary Lighting

1.02 RELATED REQUIREMENTS

- A. Section 01 31 00 - Project Management and Coordination
- B. Section 01 51 13 - Temporary Power

1.03 GENERAL REQUIREMENTS

- A. If required due to the temporary removal of any exterior or interior lighting fixtures, or due to the replacement of existing lighting fixtures, the Contractor shall furnish and install all temporary lighting including exterior security lighting of the site and make all electrical connections as required.
- B. Installation and Maintenance. The Contractor shall install the temporary lighting system and after installation shall keep it in good working order.
- C. Removal. The temporary lighting system shall be removed by the Contractor when authorized and directed by NYCHA's Designated Representative.
- D. The Contractor shall be responsible for the relocation and /or extension of the temporary lighting as required during the course of the contract work.
- E. Non-Lighting Purposes. The temporary electric lighting system shall not be used for power purposes.

PART 2 PRODUCTS (NOT USED)

PART 3 EXECUTION (NOT USED)

END OF SECTION