



## 22 14 00 Plumbing Drains

This section addresses the design requirements for Plumbing Drains.

### **Roof Drains** 22 14 26.13

Deck Type	Material Requirement
Concrete	Roof drains shall be Cast iron body, with caulked bottom outlet or non-hub outlet, weep hole, with cast iron dome strainer and a combination clamping device/gravel stop ring. Dome strainer shall be Min. 4 1/2 inch above floor. Domes shall be secured in place with stainless steel tamperproof bolts, and vandal-resistant hardware.
Wood	Same as above but with underdeck clamp.

Manufacturer Jay R. Smith, Josam, Zurn

## Canopy Drains 22 14 26.14

Deck Type	Material Requirement
DOORType	material requirement

- Concrete Cast iron body, a cast iron dome strainer and a combination clamping device/gravel stop ring. Domes shall be secured in place with stainless steel tamperproof bolts, and vandal-resistant hardware.
- Wood Same as above but with underdeck clamp.

Manufacturer Jay R. Smith, Josam, Zurn

### *Floor Drains* 22 14 26.15.

#### Interior

Location Material Requirement

General
Coated cast iron with integral double drainage flange, weep holes, sediment bucket, inside caulked bottom outlet, grate of bronze. Drain shall have 8 inch round top grate, except in finished areas where grate shall be square or rectangular to match finished surface. Drain to be in accordance with ANSI A112.6.
Compactor

Room, MER grate. and Tank

Room

# Exterior

Location	Material Requirement	
General	Coated cast iron with integral double drainage flange, weep holes, 3 inch deep sediment bucket with lift bar, inside caulked bottom outlet, vandal resistant top	
Window Areaway	Same as above except with dome grate.	
Yard Drains	Yard Drains Cast Iron 8 inch diameter body, with 6 inch deep sediment bucket, weep holes, caulked botto outlet, and 10 inch diameter flat grate.	
Manufacturer	Jay R. Smith, Josam, Zurn	

