



AT NON - PARKING AREAS

NOTES:

VERTICAL AND HORIZONTAL REBARS SHALL BE FIELD TIED. WELDING IS NOT PERMITTED. THE CONTRACTOR SHALL SUPPORT REINFORCEMENT IN ITS PROPER LOCATION FROM THE FRAMEWORK DURING CONCRETE OPERATION. THE CONTRACTOR SHALL REMOVE WATER PRESENT IN HOLE PRIOR TO POURING CONCRETE. THE CONTRACTOR SHALL VERIFY ALL INFORMATION PERTAINING TO THE POLE AND FIXTURE INSTALLATION WITH THE MANUFACTURER. THE ENGINEER AND/OR OWNER TO BE NOTIFIED OF ANY DISCREPANCIES. INSTALLATION OF POLE FOOTING IN CONCRETE PAVING REQUIRES 1/2" EXPANSION JOINT FILLER SEALED WITH JOINT SEALANT. POLE BASE DIMENSIONS, REBAR QUALITY AND SIZES TO BE AS REQUIRED TO SUIT SITE CONDITIONS, DESIGN REQUIREMENTS, SPECIFICATIONS, AND ALL CODE REQUIREMENTS. ALL CONDUIT MUST BE BURIED AT LEAST 3' BELOW GRADE. THE INFORMATION ILLUSTRATED IN THE LIGHT POLE FOUNDATION DETAIL HAS BEEN PROVIDED FOR GENERAL REFERENCE AND PRELIMINARY COST ESTIMATE PURPOSES. LIGHT POLE FOUNDATIONS SHOULD BE DESIGNED AND DETAILED BY A LICENSED STRUCTURAL ENGINEER BASED ON EXISTING SOIL CONDITIONS, LOCAL DESIGN STANDARDS AND MANUFACTURERS RECOMMENDATIONS.

Light Pole Foundation, Pole Base & Grounding Detail at Planted Areas

Not to Scale