


GENERAL NOTES:

1. SEE ELECTRICAL DRAWINGS FOR BALANCE OF WORK REQUIRED FOR INSTALLATION OF NEW LIGHT POLE.
2. CONTRACTOR TO COORDINATE WITH LIGHT POLE MANUFACTURER FOR EXACT LIGHT POLE MOUNTING CONNECTION REQUIREMENTS.
3. THE FINAL FEW INCHES OF FOOTING EXCAVATION SHALL BE MADE BY HAND OR SMOOTH TIPPED EXCAVATOR.
4. SUBGRADE SURFACE SHALL BE PROPERLY COMPACTED AND FREE OF STANDING WATER PRIOR TO PLACING REINFORCING BARS AND CONCRETE.
5. BASE PLATE SHALL BE A572, GRADE 50 & ANCHOR BOLT NUTS AND WASHERS ARE A563.
6. ALL REINFORCING BARS SHALL BE DEFORMED BILLET STEEL CONFORMING TO ASTM A615-GRADE-60. EMBEDMENTS AND SPLICES OF REINFORCEMENT SHALL COMPLY WITH REQUIREMENTS OF ACI-318.
7. AT AREA OF PARKING SPACE, THE FOOTING(S) SHALL EXTEND 2 FT ABOVE FINISHED GRADE ELEVATION. SEE PLAN FOR EXACT LOCATION(S).



Light Pole Foundation Detail

Not to Scale