



GATES SHALL BE FRAMED ON FOUR SIDES WITH 2 INCH DIA. STANDARD WEIGHT STEEL PIPE. THE GATE FRAMES SHALL BE OF ALL SHOP WELDED CONSTRUCTION WITH COMPLETE FULL WELDS GROUND SMOOTH. THEY SHALL BE THOROUGHLY CLEANED AND HOT DIPPED GALVANIZED IN ACCORD WITH A.S.T.M. SPECIFICATION A-123 AFTER FABRICATION.

GATE HINGES SHALL BE HEAVY DUTY MALLEABLE IRON FULL BACK TYPE, ALLOWING FOR 180 DEGREE SWING. GATE LOCKING DEVICE SHALL BE HEAVY DUTY EXTERNAL TYPE WITH LATCH, KEEPER AND ALL APPURTENANCES.

ALL GATES OVER 6 FEET HIGH SHALL HAVE AN INTERMEDIATE RAIL. WHEREVER A DIAGONAL BRACE CROSSES AN INTERMEDIATE RAIL THE BRACE SHALL PASS BETWEEN THE RAIL AND THE MESH.



New York City Housing Authority
 Capital Projects Division
 Design Department
 90 Church Street, 10th Floor
 New York, NY 10007

Title:

**DOUBLE GATE
 for Chain Link Fence (CLF)
 in Concrete Curb**

Contract Name:

GROUNDS REQUIREMENT

Contract No.

GD XXXXXXX

Drawn by:

G. SOUKAS

Checked by:

K. MARSHAL

Scale:

Not to Scale

Date:

January 2017

Drawing No.

CLF- 06