


GATES SHALL BE FRAMED ON FOUR SIDES WITH 2 INCH DIA. STANDARD WEIGHT STEEL PIPE. THE GATE FRAMES SHALL BE OF ALL SHOP WELDED CONSTRUCTION WITH COMPLETE FULL WELDS GROUND SMOOTH. THEY SHALL BE THOROUGHLY CLEANED AND HOT DIPPED GALVANIZED IN ACCORD WITH A.S.T.M. SPECIFICATION A-123 AFTER FABRICATION.

GATE HINGES SHALL BE HEAVY DUTY MALLEABLE IRON FULL BACK TYPE, ALLOWING FOR 180 DEGREE SWING. GATE LOCKING DEVICE SHALL BE HEAVY DUTY EXTERNAL TYPE WITH LATCH, KEEPER AND ALL APPURTENANCES.

ALL GATES OVER 6 FEET HIGH SHALL HAVE AN INTERMEDIATE RAIL. WHEREVER A DIAGONAL BRACE CROSSES AN INTERMEDIATE RAIL THE BRACE SHALL PASS BETWEEN THE RAIL AND THE MESH.

 <p>New York City Housing Authority Capital Projects Division Design Department 90 Church Street, 10th Floor New York, NY 10007</p>	Title:		<p>SINGLE GATE for Chain Link Fence (CLF) in CONCRETE CURBS</p>	
	Contract Name:		Contract No.	
<p>GROUNDS REQUIREMENT</p>		<p>GD XXXXXXX</p>		<p>Scale: Not to Scale</p>
<p>Drawn by: G. SOUKAS</p>		<p>Checked by: K. MARSHAL</p>		<p>Drawing No. CLF- 05</p>
		<p>Date: January 2017</p>		