


**NOTES:**

Precast interlocking concrete unit pavers shall have a compressive strength of greater than 8000 psi, and shall meet the requirements set forth in ASTM C936. Pigment in concrete pavers shall conform to ASTM C979.


Edge stones to be mortared in place on 2" of concrete. Stone screenings shall not exceed 1/4" diameter.

The unit pavers shall be carefully laid on the sand to insure joints are no more than 1/8". Where required, cut paving stones with an approved cutter to fit neatly and accurately without damaging edges. Sand shall be swept into joints.


The depth of the unit pavers = 2 3/8"



HERRINGBONE PATTERN



BASKET WEAVE PATTERN



RUNNING BOND PATTERN

SEE DRAWING FOR PATTERN TO BE USED



New York City Housing Authority  
 Capital Projects Division  
 Design Department  
 90 Church Street, 10th Floor  
 New York, NY 10007

Title:

**CONCRETE UNIT PAVERS  
 On Flexible Base**

Contract Name:

**GROUNDS REQUIREMENT**

Contract No.

**GD XXXXXXX**

Drawn by:  
 G. SOUKAS

Checked by:  
 K. MARSHAL

Scale:

**Not to Scale**

Date:

**January 2017**

Drawing No.

**PAV- 16**