



**NOTES -**

- ALL PIPERAIL SHALL BE 1 1/2 " O.D. 11 GAUGE D.O.M., COLD DRAWN ELECTRIC RESISTANCE WELDED STEEL TUBING, INTERNAL SLEEVES, FLUSH JOINTS.
- PIPERAIL SHALL BE PAINTED AS PER SPECS.
- ALL JOINTS SHALL BE FULLY WELDED AND GROUND SMOOTH (TYP).
- STEEL BAR FENCE (SBF) IN CHEEKWALL SHALL CONNECT TO SBF IN CURB (WHERE REQUIRED) WITHOUT FILLER PANEL.
- HANDRAIL SHALL EXTEND ONTO LEVEL PORTIONS OF STEPS 18" AT TOP AND 2'-6" AT BOTTOM.
- HANDRAIL SHALL BE CONTINUOUS ALONG FENCE FROM TOP OF STEPS TO BOTTOM OF STEPS, BOTH SIDES.



PLAN OF HANDRAIL TO POST CONNECTION

 <p>New York City Housing Authority Capital Projects Division Design Department 90 Church Street, 10th Floor New York, NY 10007</p>	<p>Title: <b>PIPE HANDRAIL on Sloped 3' Steel Bar Fence (For Steps Only)</b></p>	
	<p>Contract Name: <b>GROUNDS REQUIREMENT</b></p>	<p>Contract No. <b>GD XXXXXXX</b></p> <p>Drawn by: <b>G. SOUKAS</b></p> <p>Checked by: <b>K. MARSHAL</b></p>
		<p>Drawing No. <b>HAN- 01</b></p>