

AS CONDITIONS
 REQUIRE SEE PIPE HANDRAIL
 DETAIL (HAN-06)

NOTE:
 SEE DETAIL FOR REBAR SCHEDULE (WAL-11)

FENCE POST - SEE PLANS (HAN-05)

TOP TWO NO. 4 REBARS (HORIZ.)
 CONTINUOUS, 18" O.C.
 2" CLEAR FROM TOP OF WALL
 1 1/2" CLEAR FROM
 SIDES OF WALL

(SBF-37) MOUNTING
 PLATE

1" CHAMFER ALL SIDES

1/2" EXP. JOINT - PREMOLDED
 CLOSED-CELL POLYETHYLENE
 MATERIAL W/ SEALANT - TYP. (RAM-03)

6" REINFORCED
 CONCRETE PAVEMENT (PAV-10)

(PAV-10) 6" REINF. CONC. PAVEMENT

#5 DOWELS IN RAMP, 36" O.C.
 2" CLEAR FROM BOTTOM
 - EACH LEG 15" LONG

DRY, FIRM, UNYIELDING
 SUBGRADE - TYP.

4" STONE SCREENINGS
 TYPICAL

3/4" SMOOTH DOWELS, 24"
 LONG, 18" O.C., ONE END
 SLEEVED 12" IN WALL WITH
 PVC PIPE, CENTERED IN WALL.
 MINIMUM TWO REQUIRED AT
 EXPANSION JOINTS AND ALSO
 AT BUILDING WALL/PLATFORM
 AND STEPS.

CLEAN FILL - COMPACT
 IN 6" LIFTS

No. 4 VERT. REBARS:
 2" CLEAR TYP. (ABOVE GRADE)
 3" CLEAR TYP. (BELOW GRADE)
 24" O.C.


NOTE: ALL CONCRETE
 SHALL BE 4000 P.S.I.

No. 4 HORIZ. REBARS:
 2" CLEAR TYP. (ABOVE GRADE)
 3" CLEAR TYP. (BELOW GRADE)
 18" O.C., CONTINUOUS

FOR ADDITIONAL INFORMATION
 -SEE RAMP PROFILE &
 EXPANSION JOINT

ALIGN WITH BOTTOM OF
 OPPOSITE-SIDE CHEEKWALL
 OF LOWER RAMP.

(RAM-01) (WAL-04)

 <p>New York City Housing Authority Capital Projects Division Design Department 90 Church Street, 10th Floor New York, NY 10007</p>	Title:		<h1>RAMP CENTER CHEEKWALL</h1>
	Contract Name:	Contract No.	
<h2>GROUNDS REQUIREMENT</h2>	GD XXXXXX Drawn by: G. SOUKAS	Not to Scale Checked by: K. MARSHAL	Drawing No. <h1>RAM- 05</h1>
		Date:	
		January 2017	