

SECTION 23 01 30.51
HVAC AIR-DISTRIBUTION SYSTEM CLEANING

PART 2 PRODUCTS

1.01 TOOLS AND EQUIPMENT

- A. Vacuum Devices and Other Tools: Exceptionally clean, in good working order, and sealed when brought into the facility.
- B. Vacuum Devices That Exhaust Air Inside Building, Including Hand-Held and Wet Vacuums: Equipped with HEPA filtration with 99.97 percent collection efficiency for minimum 0.3-micron size particles and DOP test number.
- C. Vacuum Devices That Exhaust Air Outside Building, Including Truck- and Trailer-Mounted Types: Equipped with particulate collection including adequate filtration to contain debris removed from the HVAC system; exhausted in manner that prevents contaminant re-entry to building; compliant with applicable regulations as to outdoor environmental contamination.

END OF SECTION 23 01 30.51